

Section 02507 S

PRESTRESSED CONCRETE CYLINDER PIPE

The following supplements modify Section 02507 – Prestressed Concrete Cylinder Pipe Standard Specification. Where a portion of the Specification is modified or deleted by this Supplementary Specification, the unaltered portions of the Specification shall remain in effect.

2.01 PRESTRESSED CONCRETE CYLINDER PIPE: Delete Paragraph 2.01 D and replace with the following:

- D. Pipe Manufacturer: Refer to Specification Section 02511 - Water Mains for performance history requirements.

Paragraph 2.01 H.2 and replace with the following:

- 2. Rubber-Gasketed Joints: Attach joint ring to steel cylinder with full-thickness fillet welds, welded inside and out (double welded). Bond as shown on Drawings to provide electrical continuity along pipeline.

END OF SUPPLEMENT

Approved by:



Hamlet Hovsepian, P.E.
Managing Engineer
Engineering and Construction Division

Date

1/18/05